


WOOD DESTROYING PESTS AND ORGANISMS INSPECTION REPORT

| | | | |
|--|---|--|-----------------------------|
| Building Address: 9999 W. Lefty Ln., Rightway City, CA 90009 | | Date of Inspection 11/22/2011 | Number of Pages 5 |
| <div style="display: flex; align-items: center;"> <div style="flex: 1;"> <h1 style="margin: 0;">Your Pest Company inc.</h1> <p style="margin: 0;">1234 Your Street, City, CA 90000 (800) 337-2818 - www.aceapp.com</p> </div> </div> | | Report # W20153 | |
| | | Lic. Registration # PR 9999 | |
| | | Escrow # | |
| Ordered by: John Doe 9999 W. Lefty Ln. Rightway City, CA 90009 | Property Owner and/or Party of Interest: John Doe 9999 W. Lefty Ln. Rightway City, CA 90009 | Report Sent to: John Doe 9999 W. Lefty Ln. Rightway City, CA 90009 | |
| COMPLETE REPORT <input type="checkbox"/> LIMITED REPORT <input checked="" type="checkbox"/> SUPPLEMENTAL REPORT <input type="checkbox"/> REINSPECTION REPORT <input type="checkbox"/> | | | |
| General Description: Two story wood framed stucco single family residence with a composition roof and an attached garage | | Inspection Tag Posted: Garage | |
| | | Other Tags Posted: None | |
| An inspection has been made of the structure(s) shown on the diagram in accordance with the Structural Pest Control Act. Detached porches, detached steps, detached decks and any other structures not on the diagram were not inspected. | | | |
| Subterranean Termites <input checked="" type="checkbox"/> Drywood Termites <input checked="" type="checkbox"/> Fungus / Dryrot <input checked="" type="checkbox"/> Other Findings <input type="checkbox"/> Further Inspection <input type="checkbox"/> | | | |
| If any of the above boxes are checked, it indicates that there were visible problems in accessible areas. Read the report for the details on checked items. | | | |



This Diagram is not to scale

Inspected by: Sean J Chon State License No. FR 99999 Signature

You are entitled to obtain copies of all reports and completion notices on this property reported to the Structural Pest Control Board during the preceeding two years. To obtain copies contact: Structural Pest Control Board, 2005 Evergreen Street, Ste. 1500, Sacramento, California 95815.

NOTE: Questions or problems concerning the above report should be directed to the manager of the company. Unresolved questions or problems with the services performed may be directed to the Structural Pest Control Board at (916) 561-8708, (800) 737-8188 or www. pestboard.ca.gov

SECOND PAGE OF STANDARD INSPECTION REPORT OF THE PROPERTY LOCATED AT:

Address 9999 W. Lefty Ln., Rightway City, CA 90009

11/22/2011

W20153

Date

Report #

What is a Wood Destroying Pest and Organism Inspection Report?

The following explains the scope and limitations of a structural pest control inspection and a Wood Destroying Pest & Organism Inspection Report.

A Wood Destroying Pest & Organism Inspection Report contains finding as to the presence or absence of wood destroying insects or organisms in visible and accessible areas on the date of inspection and contains our recommendations for correcting any infestations, infections, or conditions found. The contents of the wood destroying pest & organism inspection report are governed by the structural pest control act and its rules and regulations.

Some structures may not comply with building code requirements or may have structural, plumbing, electrical, heating and air conditioning, or other defects that do not pertain to this report. This report does not address any such defects as they are not within the scope of the license of the inspector or the company issuing this report.

The following areas are considered inaccessible for purposes of inspection or are not included in a normal inspection report and therefore are excluded in this report: the interior of hollow walls; spaces between an upstairs floor and the ceiling below or a porch deck and soffit below; stall showers over finished ceilings; such structural segments as areas enclosed by bay windows, buttresses, built in cabinet work, areas under floor covering; any areas requiring the removal of storage, furnishings or appliances; any areas to which there is no access without defacing or removing lumber, masonry or finished workmanship.

Certain areas are recognized by the industry as inaccessible and/or for other reasons not inspected. These include but are not limited to: inaccessible and/or, insulated attics or portions thereof, attics with less than 18" clear crawl space, the interior of hollow walls; spaces between a floor or porch deck and the ceiling below; areas where there is no access without defacing or tearing out lumber, masonry or finished work; make inspection impractical; and areas or timbers around eaves that would require use of an extension ladder.

Certain areas may be inaccessible for inspection due to construction or storage. We recommend further inspection of areas where inspection was impractical. Re: Structural Pest Control Act, Article 6, section 8516 (b), paragraph 1990 (I). Amended effective March 1, 1974. Stall shower, if any, are water tested in compliance with Section 1991 (12) of the Structural Pest Control Act. The absence or presence of leaks through sub-floor, adjacent floors or walls will be reported. This is a report of the condition of the stall shower at the time of inspection only, and should not be confused as a guarantee. Although we make a visual examination, we do not deface or probe into window or door frames, decorative trim, roof members, etc., in search of wood destroying pests or organisms.

"This company will reinspect repairs done by others within four months of the original inspection. A charge, if any, can be no greater than the original inspection fee for each reinspection. The reinspection must be done within ten (10) working days of request. The reinspection is a visual inspection and if inspection of concealed areas is desired, inspection of work in progress will be necessary. Any guarantees must be received from parties performing repairs."

NOTE: We do not inspect or certify plumbing, plumbing fixtures, etc.

NOTE: "The exterior surface of the roof was not inspected. If you want the water tightness of the roof determined, you should contract a roofing contractor who is licensed by the Contractor's State License Board."

"NOTICE: The charge for service that this company subcontracts to another registered company may include the company's charges for arranging and administering such services that are in addition to the direct costs associated with paying the subcontractor. You may accept Your Pest Company Inc.'s bid or you may contract directly with another registered company licensed to perform the work.

If you choose to contract directly with another registered company, Your Pest Company Inc. will not in any way be responsible for any act or omission in the performance of work that you directly contract with another to perform."

"NOTICE: Reports on this structure prepared by various registered companies should list the same findings (i.e. termite infestations, termite damage, fungus damage, etc.). However, recommendations to correct these findings may vary from company to company. You have a right to seek a second opinion from another company."

This Wood Destroying Pest & Organisms Report DOES NOT INCLUDE MOLD or any mold like conditions. No reference will be made to mold or mold-like conditions. Mold is not a Wood Destroying Organism and is outside the scope of this report as defined by the Structural Pest Control Act. If you wish your property to be inspected for mold or mold like conditions, please contact the appropriate mold professional.

"Local treatment is not intended to be an entire structure treatment method. If infestations or wood-destroying pests extend or exist beyond the area(s) of local treatment, they may not be exterminated."

Address 9999 W. Lefty Ln., Rightway City, CA 9000911/22/2011W20153

Date

Report #

This is a separated report which is defined as Section I/Section II conditions evident on the date of the inspection. Section I contains items where there is visible evidence of active infestation, infection or conditions that have resulted in or from infestation of infection. Section II items are conditions deemed likely to lead to infestation or infection but where no visible evidence of such was found. Further inspection items are defined as recommendations to inspect area(s) which during the original inspection did not allow the inspector access to complete the inspection and cannot be defined as Section I or Section II.

FINDINGS AND RECOMMENDATIONS

NOTE: This is a limited inspection report requested by the owner, limited to the inspection of the subarea, garage, and exterior only. Note - It is recommended that further inspection of the entire structure be made in accordance with Structural Pest Control regulations.

Substructure: Concrete slab construction - see report for terms and conditions

1A (Section I)
FINDINGS: Evidence of subterranean termite infestation at subarea as indicated on the diagram.
RECOMMENDATION: Pressure "ROD" treat, trench application or low pressure spot spray as necessary. Break accessible sub tubes.

1B (Section I)
FINDINGS: Surface fungus condition visible at time of inspection at subarea as indicated on the diagram.
RECOMMENDATION: Scrape and chemically treat fungus condition. Patch any minor surface damage found during treatment.

Garages: Two car attached. In cases of areas covered by draw wall and/or cabinets, these areas were impractical for inspection. In cases of areas covered by storage, these areas were not inspected; further inspection recommended after storage is removed.

8A (Section I)
FINDINGS: Evidence of dry-wood termite infestations at garage as indicated on the diagram.
RECOMMENDATION: Vacate the premises and seal the structure for fumigation with Vikane Gas. Remove or cover accessible evidence of infestation. Fumigation warranted for two years. Fumigation awareness notice must be signed prior to fumigation. See fumigation notice for terms and liabilities.

Other Interior: Not inspected

Other Exterior: Inspected visible and accessible areas. See report for terms and conditions.

11A (Section I)
FINDINGS: Evidence of dry-wood termite infestations at exterior window trim as indicated on the diagram.
RECOMMENDATION: Vacate the premises and seal the structure for fumigation with Vikane Gas. Remove or cover accessible evidence of infestation. Fumigation warranted for two years. Fumigation awareness notice must be signed prior to fumigation. See fumigation notice for terms and liabilities.

11B (Section I)
FINDINGS: Evidence of termite damaged wood members noted at time of inspection at fascia as indicated on the diagram.
RECOMMENDATION: Replace termite damaged wood members as necessary. No painting is included in this estimate.

FOURTH PAGE OF STANDARD INSPECTION REPORT OF THE PROPERTY LOCATED AT:

Address 9999 W. Lefty Ln., Rightway City, CA 90009

11/22/2011

W20153

Date

Report #

In accordance with the laws and regulation of the State of California, we are required to provide you with the following information prior to application of pesticides to your property.

"State law requires that you be given the following information: CAUTION--PESTICIDES ARE TOXIC CHEMICALS. Structural Pest Control Companies are registered and regulated by the Structural Pest Control Board, and apply pesticides which are registered and approved for use by the California Department of Pesticide Regulation and the United States Environmental Protection Agency. Registration is granted when the state finds that, based on existing scientific evidence, there are no appreciable risks if proper use conditions are followed or that the risks are outweighed by the benefits. The degree of risk depends upon the degree of exposure, so exposure should be minimized."

"If within 24 hours following application you experience symptoms similar to common seasonal illness comparable to the flu, contact your physician or poison control center (800) 876-4766 and your pest control company immediately." "For further information, contact any of the following:

For further information, contact any of the following:

Your Pest Company Inc. (800) 123-1234

Poison Control Center (800) 876-4766

(Health Questions) County Health Dept.
Orange County (714) 834-7700
Los Angeles County (213) 250-8055
San Bernardino County (909) 387-6280
Riverside County (909) 358-5000

(Application Info.) County Agriculture Commission
Orange County (714) 447-7100
Los Angeles County (626) 575-5465
San Bernardino County (909) 387-2115
Riverside County (951) 955-3000

Structural Pest Control Board (Regulatory Info.) (916) 561-8704
2005 Evergreen Street, Ste. 1500 Sacramento, CA 95815

TERMITE AND FUNGUS CONTROL CHEMICALS

Termidor SC (EPA Reg. No. 7969-210)

Active Ingredients: Fipronil:5-amino-1-(2,6-dichloro-4-(trifluoromethyl)phenyl)-4-((1,R,S)-(trifluoromethyl)sulfinyl)-1-H-pyrzole-3-carbonitrile 9.1%

Tim-bor (EPA Reg. No. 1624-39)

Active Ingredients: Disodium Octaborate Tetrahydrate 98%

Vikane (EPA Reg. No. 62719-4)

Active Ingredients: Vikane-sulfuryl floride 99.5%, Chloropicrin .5%

NOTICE TO OWNER

Under the California Mechanics Lien Law any structural pest control company which contracts to do work for you, any contractor, subcontractor, laborer, supplier or other person who helps to improve your property, but is not paid for his or her work or supplies, has a right to enforce a claim against your property. This means that after a court hearing, your property could be sold by a court officer and the proceeds of the sale used to satisfy the indebtedness. This can happen even if you have paid your structural pest control company in full if the subcontractor, laborers or suppliers remain unpaid.

To preserve their right to file a claim or lien against your property, certain claimants such as subcontractors or material suppliers are required to provide you with a document entitled "Preliminary Notice." Prime contractors and laborers for wages do not have to provide this notice. A Preliminary Notice is not a lien against your property. Its purpose is to notify you of persons who may have a right to file a lien against your property if they are not paid.

NOTE: If the Home Owner fails to pay billing in full, Your Pest Company Inc. will have the right to be paid back for all its costs and expenses to the extent not prohibited by applicable law. Those expenses include, for example (but not limited to), reasonable attorney's fees. If for any reason this account is to be turned over to our collection agency, You will be responsible for all cost of collecting.

Address 9999 W. Lefty Ln., Rightway City, CA 90009

11/22/2011

W20153

Date

Report #

Findings and Recommendations estimated by this Company:

| Item | Approval | Primary Estimate | Section |
|------|--------------------------|------------------|---------|
| 1A | <input type="checkbox"/> | \$350.00 | I |
| 1B | <input type="checkbox"/> | \$80.00 | I |
| 8A | <input type="checkbox"/> | \$1,200.00 | I |
| 11A | <input type="checkbox"/> | Included in 8A | I |
| 11B | <input type="checkbox"/> | \$250.00 | I |

Complete all of the items quoted above with Primary Estimate.

Total Estimate \$1,880.00

Complete only the above Items checked.

Total \$ _____

I have read and understand the terms of the Report referenced above and agree to the terms and conditions set forth. Your Pest Company Inc. is hereby authorized to complete the Items selected above and it is agreed that payment shall be made as follows:

Payment shall be made as follows: With close of Escrow \$ _____ Deposit \$ _____ on Completion

Escrow Number: _____ Escrow Company: _____ Escrow Officer: _____

Phone () _____ - _____ Fax () _____ - _____ Address: _____

Owner or Authorized Representative: Owner Representative's Title: _____

Print Name: _____ X _____ Date _____

Owner or Authorized Representative: Owner Representative's Title: _____

Print Name: _____ X _____ Date _____

